



DSG NPS Status Update

Aaron Brown and the
Detector Support Group
December 1, 2022

Contents

- Thermal Readback
- Low Voltage Controls & Monitoring
- Keysight D-sub Extension Cables
- Conclusion

























Thermal Readback

- Thermal readback Phoebus screen testing in progress
 - Screens uploaded to *cdaq/3*
 - Number of issues converging to zero

By:	Pablo Campero						
Date:	11/29/2022						
Project:	NPS CSS-Phoebus Screen Test						
#	Screen Name	Status	Test I Comments	Status	Test II Comments	Status	Test III Comments
1	Front Crystal Zone Temperature Sensors Monitoring	Completed	No Interlock Status or Latch Status indicator works	Completed	<ul style="list-style-type: none"> Average values do not show expected values when the set # of points to average =1 Out of limit indicators do not change to red when readback is below low limit 	Completed	Average value does not change when # of points to average is > 1; average value = sensor value
2	Front Crystal Zone Temperature Sensors Controls	Completed	Sensor Enable buttons do not work; remain in off position	Completed		Completed	
3	Back Crystal Zone Temperature Sensors Monitoring	Completed	No Interlock Status or Latch Status indicator works	Completed	<ul style="list-style-type: none"> Average values do not show expected values when the set # of points to average =1 Out of limit indicators do not change to red when readback is below low limit 	Completed	Average value does not change when # of points to average is > 1; average value = sensor value
4	Back Crystal Zone Temperature Sensors Controls	Completed	<ul style="list-style-type: none"> Sensor Enable buttons do not work; remain in off position Trip delay PV disconnected 	Completed		Completed	

Low Voltage Controls & Monitoring


Low Voltage Control and Monitoring

Card	Channel	Power	V Set	V Readback	I Set	I Readback
0	0	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	1	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	2	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	3	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	4	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	5	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	6	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	7	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
1	0	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	1	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	2	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	3	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	4	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	5	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	6	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	7	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
2	0	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	1	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	2	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	3	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	4	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	5	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	6	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_
	7	 Off	<hcnps_	<hcnps_	<hcnps_	<hcnps_

<sys://time>

- Tested IOC and received data from MPOD
- Currently, development version of IOC on cdaq13
 - IOC set up to only readback voltage and current – full control and monitoring will be made available for production version
 - Any production version files should be put in a directory in the EPICS base path

Keysight D-sub Extension Cables



Conclusion

- Thermal readback Phoebus screens debugging in progress
- EPICS IOC for low voltage controls and monitoring has been developed and tested
 - Phoebus GUI has been developed

THANK YOU!