


- NOTES:
- TAH: TEMP ALARM HIGH
 - PAH: PRES ALARM HIGH
 - TI: TEMP INDICATOR
 - TS: TEMP SENSOR
 - FC: FLOW CONTROLLER
 - HA: HAND ACTUATED
 - PRV: PRES REG VALVE
 - E: HEAT EXCHANGER
 - FSD: FAST SHUTDOWN
 - CV: CONTROL VALVE
 - FS: FLOW SWITCH
- M ON VALVE: MOTOR CNTL
 TS6: LAKESHORE PLATINUM RTD PAIR
 TS5: LAKESHORE CERNOX PAIR PID HEATER ON TS5
 TS2: PID CV-3 ON TS2



General Notes

- APPLICABLE CODE: ASME B31.3 2014
- FLUID CATEGORY: NORMAL

No.	Revision/Issue	Date

Drawing Name: P&ID
 PS-TGT-14-001

Project Name and Address:
 Tritium Target
 Hll A Tritium Target

Area EXPERIMENTAL HALL A	Stamp
Drawing Number TGT-103-1001-0000	
Author D. Meekins	