
Engineering Status






Topics

- KPT
 - Design Status
 - Cooling and Contamination
 - Civil Construction Requirements
 - Cost and Schedule
 - Decommissioning Plan
- CPS
 - Design Status
 - Cooling and Contamination
 - Civil Construction Requirements
 - Cost and Schedule
 - Decommissioning Plan
- Flux Monitor
 - Design Status


Hall D K-Long Engineering Status Sept 2023 - Presented by Tim Whitlatch




Hall D Collimator Cave Layout for KPT




Need to add rails for removal upon end of Hall D runs



Beryllium Target Assy (fully encapsulate Be target



Beryllium Target Section (need to fill corners for lifting




KPT Design Requirements/Specs

- Irradiated portion remain shielded during de-install
- Berylium Target
 - 6cm diameter
 - > 40 cm length
 - 300W power absorption
 - Water cooled- separate chiller system
- Tungsten absorber
 - > 15.24 cm square
 - > 10cm length
 - > 5.2KW power absorption
 - Water cooled separate Chiller system required


Tungsten Absorber Thermal Analysis

- Power absorption data provided by Vitaly Baturin
- Modelled in ANSYS Static Thermal
- ► Shows maximum delta T of 117C
- Outer Surface cooled with water under 100C
- ► Maximum Tungsten Temp 216C


3D Rendering - cooling plates on 4 sides - Max water temp less than 50C - 4 circuits



Tungsten Absorber 5.2 KW total input - 2 W/m^2 convection US face - 80C air temp



Berylium Target Water Cooled




Cooling System For KPT Target and Absorber

- > 5.2 Kw from Tungsten
- > 300 watts from Berylium
- Separate 6Kw Chiller recirculated water stays in Hall
- <3 gpm required</p>
- ▶ Delta T of water less than 10C
- ► Tungsten has 4 circuits, beryllium 1 circuit

KPT Design Status

- ► Initial design complete
 - Need to redesign for removal assuming center is radioactive
- Need to finalize Collimator or Profiler




Klong Collimator Cave COSTS				
Equipment	qty	cost ea \$	Fab cost \$	Total cost \$
Beryllium target	1	15,000		15,000
Beryllium support	1	1,100		1,100
Tungsten absorber	1	15,000		15,000
Target Lead Bricks (painted)	1190	62	2000	75,780
Target Support structure (to lift)	1	0	14000	14,000
Hilman rollers	4	850		3,400
Horizontal Rails	2		1850	1,850
wedge levelers	4	700		2,800
Longitudinal rails for final removal	2	2500	4000	9,000
leveler base plate	4		2100	2,100
borated poly sheets	24	800	4800	24,000
Central support tubes	2	800		1,600
Hardware	76	2.5		190
cooling plates	4	1240		4,960
Water cooling system	1	20000		20,000
Shielding wall lead bricks (painted)	792	62		49,104
vacuum beamline	1	5000		5,000
Concrete block shielding wall	1188	6		7,128
Water cooling for beryllium	1	1000		1,000
Active collimator stand	1	10000		10,000
PLC	1	2000		2,000
Temperature sensors and PLC comp	6	150		900
Support for shield wall	2	3300		6,600
Total cost				272,512

KPT Installation

Task	Duratio n						Faciliti	
	n	_						
		Eng	Tech	E	ng	Tech	es	S&A
Remove old Equipment								
Beamline	2		.1	3	0.0008			
Profiler	1		.1	2	0.0004			
Primary Collimator	1		.1	2	0.0004			
Secondary Collimator	2		.1	3	0.0008			
Move North Cable Tray	1		.1	2	0.0004			
Permanent Magnet	2		.1	3	0.0008			
Polarimeter	2		.1	3	0.0008			
Stands	2	. 0	.1	2	0.0008	0.0	2	
Install KPT								
Rails on Floor	3	0	.2	2	0.0024	0.0	2	0.01
Target Support Structure	2	. 0	.3	3	0.0024	0.0	2	0.01
Bottom layers of target shielding	10	0	.2	4	0.008	0.1	6	
Beryllium Target	1	. 0	.2	2	0.0008	0.0	1	
Tungsten Absorber	1	. 0	.2	2	0.0008	0.0	1	0.01
Hook up cooling system and leak check	5	0	.1	2	0.002	0.0	4	
Remaining target shielding	10	0	.3	4	0.012	0.1	6	
New Profiler/Collimator	3	0	.2	2	0.0024	0.0	2	0.01
1st shielding wall	10	0	.2	4	0.008	0.1	6	
2nd shielding wall	10	0	.1	4	0.004	0.1	6	0.01
Permanent magnet	4	0	.1	4	0.0016	0.0	6	0.01
Beamline	5	0	.1	3	0.002	0.0	6	0.01
Test all systems	10	0	.2	1	0.008	0.0	4	
Totals	87	,			0.0596	1.0	7 (0.04
Duration in months	4.35							
Techs required for duration (ave)	2.95							
Eng required for duration (ave)	0.16							
Designer for needed modifications	0.1							
Hall D K-Lo Techs with overhead for safety and training	3.54	•						
Jefferson Lab								


CPS in Tagger Hall



Hall D K-Long Engineering Status Sept 2023 - Presented by Tim Whitlatch



Temperature profile from Pavel 76 power, 0.2mm mesh at bottom, 51.4 KW





Thermal Stress - copper absorber C101 Full Hard

- Strain = Alpha * delta T
- Stress = Youngs Modulus * Strain
- Strain = 1.674ee-5/C * 134C = .0022
- Stress = 1.26 ee11 Pa * .0022 = 280 MPa
- ► Allowable yield stress = 283 Mpa

Cooling System For CPS

- ▶ 52 Kw from Copper Absorber
- Use existing dump cooling system - recirculated water stays in Hall
- ▶ 30 gpm required
- Delta T of water less than 8C
- 4 water cooling channels minimum
- Maximum temperature at water cooling channels 98C
- ▶ 2 parallel circuits



CPS Cost Estimates

Klong Compact Photon Source - Pavel 75 ma	terial					
					Fab cost	
Component	qty	Lbs	Kg	cost ea \$	\$	Total cost \$
Copper absorber	1	1916	869.864	33000	C	33,000
WCu absorbers	138.32	3458	1569.93	1,500		207,480
Lead Bricks (painted)	2220.423	57731	26209.9	62	2000	139,666
borated poly sheets	89.48125	14317	6499.92	800	35792.5	107,378
Iron core	1	3370	1529.98	16850	10,000	26,850
Iron shield	1	27555	12510	137775	10,000	147,775
Barite concrete (CPS and beamline)	893.926	55132	25029.9	42	10,000	47,545
Adjustment components	3			2800		8,400
Support Structure	1	2000)	30000		30,000
Lifting box (radiation containment portion)	1			14000		14,000
Rail System	1			4000		4,000
Water Cooling System	1			5000		5,000
Beamline Plus girder	1			10000		10,000
Radiator (3 position remotely)	1			15000		15,000
Magnet	1	2202.65	1000	110000		110,000
Power Supply	1			100000		100,000
Machining of shielding components	1			15000		15,000
Concrete pier	1			20000		20,000
Temperature sensors and wires	20			200		4,000
Vacuum Pump and controllers	1			20000		20,000
PLC modules and shielding	5			1500		7,500
Total Materials		167681.65	75219.5			1,072,594



CPS Required Design Manpower

KLONG CPS Design							
·	Days	#		#	FTE	FTE	FTE
Task	Duratio	n Eng	Į	Des	Eng	Des	Facilities
Design new beamline					J		
Beamline layout	1	0	0.1	1	C	0.04	
Perm Magnet setup		2	0.1	1	C	0.01	
Vacuum pump setup		2	0.1	1	C	0.01	
Final Beamline drawings	2	5	0.2	1	0.02	0.1	
Component procurement	20	0	0.05	0.05	0.04	0.04	
Design CPS							
Design Concrete Base	3	0	0.2	1	0.02	0.12	0.12
Design rails	1	5	0.3	1	0.02	0.06	
Design support structure/strongback	2	5	0.4	1	0.04	0.1	
Design adjustment system		5	0.1				
Design magnets	6		0.4				
Procure Magnets and Power Supplies	25	n	0.1	0.1	0.1	0.1	
Design radiator		5	0.1				
Design shielding	12		0.2				
Test Magnets		5	0.2				
Design alignment system		5	0.2		_		
Design cooling system		0	0.4				
Procure all shileding components	20	0	0.1	0.05	0.08	0.04	
Procure rails, strongback and cooling	20	0	0.1	0.05	0.08	0.04	
Procure radiator components		0	0.1				
Installation Drawings		0	0.1				
		4 -			0.7	2.44	0.40
Totals Duration in months		4 Da	ys		0.76	2.11	0.12
Duration in months Per required for duration (200)	21. 1.2						
Des required for duration (ave)							
Eng required for duration (ave)	0.4	J					






CPS Installation

KLONG CPS Installation										
	Days	į	#		#	FTE		FTE	FTE	FTE
Task	Duration		Eng		Tech	Eng	j	Tech	Facilities	S&A
Remove old equipment										
Crates		5		0.1		3	0.002	0.06		
microscope		3		0.1		3	0.0012	0.04		
Hodoscope		3		0.1		2	0.0012	0.02		
Beamline		5		0.2		3	0.004	0.06		
Install CPS										
Install Concrete Base		10		0.1		1	0.004	0.04	0.12	2
Install rails		4		0.3		3	0.0048	0.05		0.01
Install support structure		10		0.3		3	0.012	0.12		0.02
Install magnets		10		0.2		3	0.008	0.12		
Install Power Supplies		5		0.1		3	0.002	0.06		
Survey and alignment		2		0.2		1	0.0016	0.01		0.01
Install radiator		2		0.3		2	0.0024	0.02		0.01
Install partial shielding		20		0.2		4	0.016	0.32		
Test Magnets		5		0.2		2	0.004	0.04		
Survey and Alignment		2		0.2		1	0.0016	0.01		0.01
Install remaining shielding		20		0.2		4	0.016	0.32		
Install cooling system		10		0.4		3	0.016	0.12		
Install Perm Magnet		4		0.2		3	0.0032	0.05		0.01
Install beamline & windows		5		0.2		3	0.004	0.06		
Install New Girder		3		0.1		3	0.0012	0.04		0.01
Setup and test controls		20		0.1		1	0.008	0.08		
Final Survey		2		0.1		1	0.0008	0.01		0.01
Totals		150					0.114	1.63	0.12	0.07
Duration in months		7.5								
Techs required for duration (ave)		2.61			<u></u>	١.		, ,		
Eng required for duration (ave)		0.18			Plu	s F	Iall W	Vork		
					Cor	\rd	inato	r		
Techs with overhead for safety and training		3.13				JI U	iiialu			

Civil/RadCon requirements

- Irradiated portion must be shielded during removal
- Collimator Floor Capable of supporting additional 120+ Tons
- Tagger Hall Floor Capable of supporting additional 120+ Tons
 - Facilities will re-evaluate when final weight is determined
 - ► Facilities to install concrete pier

Conceptual Flux Monitor Setup in Hall D



Proposed MRI Magnet can fit in existing space and platform can support the weight

Decommissioning

- CPS
 - Roll CPS to South wall in the Tagger Vault
 - Remove CPS beamline and shielding
 - Reinstall GlueX beamline
 - Reinstall Hodoscope, Microscope and electronics
 - Reinstall Dump cooling
 - 6 months duration
- KPT
 - Roll Target to North wall
 - Remove KPT shielding and beamline
 - Reinstall GlueX beamline
 - 4 months duration
- KFM
 - Remove KFM setup
 - ► Reinstall Gluex beamline, detectors and target
 - 1-3 months duration



Status

- Collimator Cave Final Drawings 95% Complete can be found here O:\halld_engineering\KLONG\COLLIMATOR CAVE\DRAWINGS EXPORT 5-22-23
- Preliminary Thermal Analysis ongoing for CPS
- Final Stress analysis for CPS required
- ► Integrated Installation Plan Needed
- ► Flux Monitor in Conceptual Phase Proposed MRI will fit
- CPS Design Work to start Following ERR Approval
- ► Hall D hiring an additional Engineer

Backup





Cave Layout Elevation

